

Certificate of Test

*We hereby declare that the item described below
has been tested by BSI and
complies with the requirements of*

*BS EN 60529: 1992 Specification for Degrees of protection by enclosures (IP Code). For
a Classification of IP68 Category 1, protection against ingress of solid foreign objects
(dust tight) and protection against ingress of water (continuous immersion)*

*The full details of the tests and the results are given in
our Report No: 288/4064881 Dated: 25 November 1999*

Description of item tested: Cable joint enclosures
Type BS3/2+CS3/2/C
Type BS1/2+CS4/C

Submitted by: PTC
Mill Chase Barn Wildings Lane
Steeple Bumpstead Haverhill
Suffolk CB9 7EQ

Certificate authorised by:

R. J. Wells

Title

Laboratory Manager

Date

25 November 1999



TESTING
No. 0135

*Attention is drawn to the conditions upon which this
declaration is issued, namely:*

*1. The general and specific conditions of the BSI Product
Services, Test Leaflet 1 apply in all respects. Copies of
this leaflet are available on request.*

*2. This Declaration applied only to the particular sample
tested and to the specific tests carried out as detailed in
the Report referred to above.*

*3. This declaration does not indicate any measure of
Approval, Certification, Supervision, Control or
Surveillance by BSI to this or any related product.*

BSI Product Services, Maylands Avenue, Hemel Hempstead, Hertfordshire HP2 4SQ